



EDUCATING
TOMORROW'S
PIONEERS

400 North Highland Creve Coeur, Illinois 61610-3137 • (309) 698-3600

Dear Parent(s)/Guardian(s):

This letter is to notify you that Creve Coeur School District #76 did a lead sample test at LaSalle School.

Senate Bill 550 requires schools to conduct an analysis to detect lead content in water. Under the Safe Drinking Water Act... fountains, faucets, etc. emitting water containing (15) or more micrograms per liter of water are to develop an action plan to remedy such issue.

LaSalle School received test results that conveyed concentrations below (15) or more micrograms per liter of water. According to rules and regulation of the Illinois Department of Public Health, schools are required to provide parents/guardians with direct notification when concentrations are greater than (5) or more micrograms per liter of water. Once again, LaSalle School received test results that conveyed concentrations well below (15) or more micrograms per liter of water. We are providing direct notification to our parents/guardians to comply with the rules and regulations of the Illinois Department of Public Health.

If any of the sample results exceed 5 ppb, schools must notify parents in writing or electronically. There was only one reading over 5 ppb at LaSalle School and that was in the Kitchen Dishwasher on the 1st reading of 6.46. On the second reading at the Kitchen Dishwasher the reading was a 1.27.

<u>Floor / Description</u>	<u>Location</u>	<u>Concentration ppb</u>
First Floor LaSalle	Kitchen Dishwasher 1 st Sample	6.46
First Floor LaSalle	Kitchen Dishwasher 2 nd Sample	1.27

Parents should contact their health care provider with any concerns about their child's health concerning lead exposure.

Creve Coeur School District #76 top priority is always to keep your children safe.

Feel free to call the Board Office at 309-698-3600 if you have any questions regarding this survey. All results of the lead testing at LaSalle School are on the back of this letter.

Sincerely,

A handwritten signature in cursive script that reads "Tony Whiston".

Tony Whiston, Superintendent
Creve Coeur Schools

Lead Testing at LaSalle Elementary School
August 30, 2017

Description	Location	Sample	Concentration <i>ppb</i>
Fountain #1	Kindergarten	1st	ND
Fountain #1	Kindergarten	2nd	1.31
Fountain #2	Kindergarten	1st	1.28
Fountain #2	Kindergarten	2nd	1.41
Fountain #3	Cafeteria Hall	1st	1.63
Fountain #3	Cafeteria Hall	2nd	1.36
Fountain #4	Office Hall	1st	1.05
Fountain #4	Office Hall	2nd	ND
Fountain #5	Office Hall	1st	ND
Fountain #5	Office Hall	2nd	1.08
Fountain #6	Outside Gym	1st	1.14
Fountain #6	Outside Gym	2nd	1.15
Sink	Kitchen	1st	2.16
Sink	Kitchen	2nd	1.27
Dishwasher	Kitchen	1st	6.46
Dishwasher	Kitchen	2nd	1.58
Sink	Kindergarten/Battles	1st	1.50
Sink	Kindergarten/Battles	2nd	1.37
Sink	Kindergarten/Head Start	1st	1.88
Sink	Kindergarten/Head Start	2nd	1.68
Sink	Kindergarten/Bales	1st	1.45
Sink	Kindergarten/Bales	2nd	4.20
Sink	Kindergarten/Stetler	1st	1.76
Sink	Kindergarten/Stetler	2nd	1.64



How to interpret your test results

1. Test results will be reported in either parts per billion (ppb) or micrograms per liter (ug/l). Both units of measure are appropriate.
2. If any sample exceeds 5 ppb of lead, the notification requirements are triggered.