



EDUCATING  
TOMORROW'S  
PIONEERS

400 North Highland Creve Coeur, Illinois 61610-3137 • (309) 698-3600

Dear Parent(s)/Guardian(s):

This letter is to notify you of the Creve Coeur District #76 lead testing results.

Senate Bill 550 requires schools to conduct an analysis to detect lead content in water. Under the Safe Drinking Water Act... fountains, faucets, etc. emitting water containing (15) or more micrograms per liter of water are to develop an action plan to remedy such issue.

Parkview School received test results that conveyed concentrations below (15) or more micrograms per liter of water. According to rules and regulation of the Illinois Department of Public Health, schools are required to provide parents/guardians with direct notification when concentrations are greater than (5) or more micrograms per liter of water. Once again, Parkview School received test results that conveyed concentrations well below (15) or more micrograms per liter of water. We are providing direct notification to our parents/guardians to comply with the rules and regulations of the Illinois Department of Public Health.

If any of the sample results exceed 5 ppb, schools must notify parents in writing or electronically. There were two areas where the reading was over 5 ppb at Parkview School.

<u>Floor / Description</u>	<u>Location</u>	<u>Concentration ppb</u>
1 <sup>st</sup> Floor Water Fountain	Rm. 106 (Ms. Melissant)	9.12
2 <sup>nd</sup> Floor Water Fountain	Rm. 210 (Mr. Klesner)	7.86

Parents should contact their health care provider with any concerns about their child's health concerning lead exposure.

Creve Coeur School District #76 top priority is always to keep your children safe.

Feel Free to call the Board Office at 309-698-3600 if you have any questions regarding this survey. All results of the lead testing at Parkview School are on the back of this letter.

Sincerely,

A handwritten signature in cursive script that reads "Tony Whiston".

Tony Whiston, Superintendent  
Creve Coeur Schools

Lead Testing at Parkview, August 30, 2017

Floor/Discription		Location	1 <sup>st</sup> /2 <sup>nd</sup>	Concentration
1 <sup>st</sup> Floor Water Fountain	A1	Across from Office	1 <sup>st</sup> Sample	1.32
1 <sup>st</sup> Floor Water Fountain	A1	Across from Office	2 <sup>nd</sup> Sample	1.44
1 <sup>st</sup> Floor Water Fountain	A2	Melissants Room	1 <sup>st</sup> Sample	8.90
1 <sup>st</sup> Floor Water Fountain	A2	Melissants Room	2 <sup>nd</sup> Sample	9.12
1 <sup>st</sup> Floor Water Fountain	A3	By Locker Rooms	1 <sup>st</sup> Sample	2.82
1 <sup>st</sup> Floor Water Fountain	A3	By Locker Rooms	2 <sup>nd</sup> Sample	3.54
1 <sup>st</sup> Floor Water Fountain	A4	By Cafeteria (on Right)	1 <sup>st</sup> Sample	ND
1 <sup>st</sup> Floor Water Fountain	A4	By Cafeteria (on Right)	2 <sup>nd</sup> Sample	1.08
1 <sup>st</sup> Floor Water Fountain	A5	By Cafeteria (on Left)	1 <sup>st</sup> Sample	ND
1 <sup>st</sup> Floor Water Fountain	A5	By Cafeteria (on Left)	2 <sup>nd</sup> Sample	1.11
<hr/>				
2 <sup>nd</sup> Floor Water Fountain	B1	By Restrooms	1 <sup>st</sup> Sample	1.40
2 <sup>nd</sup> Floor Water Fountain	B1	By Restrooms	2 <sup>nd</sup> Sample	2.31
2 <sup>nd</sup> Floor Water Fountain	B2	By Kluesner	1 <sup>st</sup> Sample	7.61
2 <sup>nd</sup> Floor Water Fountain	B2	By Kluesner	2 <sup>nd</sup> Sample	7.86
<hr/>				
1 <sup>st</sup> Floor - Sink in Kitchen	K1	Kitchen	1 <sup>st</sup> Sample	3.28
1 <sup>st</sup> Floor - Sink in Kitchen	K1	Kitchen	2 <sup>nd</sup> Sample	1.99
1 <sup>st</sup> Floor - Dishwasher in Kit.	K2	Kitchen	1 <sup>st</sup> Sample	2.24
1 <sup>st</sup> Floor - Dishwasher in Kit.	K2	Kitchen	2 <sup>nd</sup> Sample	1.55